

AUG 21 1987

Title 161 - STATE FIRE MARSHAL

Chapter 2 - INSPECTIONS

001. Periodic safety inspections shall be conducted by State Fire Marshal personnel, based on the safety requirements found in the NFPA 61A and 61B codes adopted by the State Fire Marshal.

001.01. Inspections shall include, but not be limited to, the following: leg casings, head and boot sections, connecting spouts; power connections to motors, winches and conveyors; covering and lubrication of bearings; clutches and drive belts; dryers, air screens and exhaust systems; dust collection systems, drying areas and fuel supplies; motor grounding, augers, belt drives; extinguishers; no smoking prohibition; storage areas; feed grinding and processing machinery; head house sprinklering; electrical (for National Fire Protection Association code); general housekeeping.

002. There shall be no charge for the initial inspection and one call-back inspection. Should additional call-back inspections be needed to assure compliance, there will be a \$25.00 charge for each additional inspection.

Legal Citation: Title 161, Chapter 2, State Fire Marshal